



NOTE:

1. ALL METAL PARTS CORROSION RESISTANT. NON-GALVANIZED PARTS PREFERRED, STAINLESS STEEL PARTS AND ALUMINUM ARE ACCEPTABLE. ALL GALVANIZED PARTS TO HAVE ASPHALT TREATMENT 1.
2. DISTANCE BETWEEN ACCESS MANHOLES AND ANY POINT WITHIN THE STRUCTURE SHALL BE NO GREATER THAN 50' MAX.
3. ONE ACCESS RISER MINIMUM FOR ALL TANKS.
4. NO INLET PIPES SHALL BE WELDED TO THE SIDES OF TANKS; ALL CONNECTIONS SHALL BE THROUGH CBS.

CITY OF KIRKLAND

PLAN NO. CK-D.34



DETENTION TANK